



- NOTES:
- < 1 TO REGULATOR THRU POWER I/F PC BOARD.
 - < 2 CONTACTS ON RELAY RECTIFIER PC BOARD.
 - < 3 REMOVE JUMPER WHEN DB OPTION USED.
 - < 5 SUPPLIED WITH S6R ONLY.
 - < 6 FOR NOTE, SEE SHEET 3.
 - < 7 FOR NOTE, SEE SHEET 3.
 - < 8 KIT SEPARATELY MOUNTED.
 - < 16 FOR NOTE, SEE SHEET 3.
 - < 18 FOR S6 DRIVES, THE A1 CONNECTION TO 11FU IS REPLACED BY A JUMPER BETWEEN 47(+) AND A1 ON THE POWER I/F BOARD.
 - < 19 KIT MOUNTED IN/ON POWER CHASSIS.

SCHMATIC FOR
40 THRU 75HP AT 230VAC
75 THRU 150HP AT 460VAC

- ⊠ FASTON CONNECTOR
- TP TWISTED PAIR
- PX-X PLUG TERMINAL CONNECTION
- TERMINAL CONNECTION

12	-01 N/R 500357
11	-01 N/R 500357
10	-01 N/R 500357
9	-01 N/R 500357
8	-01 N/R 500357
7	-01 N/R 500357
6	-02 C/R 357687
5	-02 C/R 357687
4	-01 N/R 500357
3	-02 C/R 357687
2	-02 C/R 357687
SHEET	REV STATUS

C/R	357687
DATE	1-9-98
SEE C/R	REV -02
N/R	500357
DATE	11-8-96
SEE N/R	BODY

RELIANCE ELECTRIC
RELIANCE ELECTRIC INDUSTRIAL COMPANY • CLEVELAND, OH 44117

WIRING DIAGRAM BULLETIN 1397
S6/S6R 75/150HP 230/460VAC

DR. TLS	DATE 11-8-96	SCALE: NONE
CK. MWQ	ENG'R JEB	SHEET 1 OF 12
APP. TMC	DISTRIBUTION 13-688-76	W/D 30372-23